## **ADDENDUM 04**

Contract # 24-S-04

Dated: July 22, 2024

The foregoing documents are amended in the respects as herein set forth. This addendum and the amendments herein shall become part of said documents and of any contract entered into pursuant to said documents.

PLEASE ACKNOWLEDGE THIS ADDENDUM ON YOUR PROPOSAL. IF YOU HAVE GIVEN THE CONTRACT DOCUMENTS TO SOMEONE ELSE, PLEASE FORWARD THIS ADDENDUM.

PROFESSIONAL C. HARDER STATE OF CALFORNIA

Jul 22, 2024

Date Signed

**Engineer of Record:** 

Joseph C. Harrell, PE C80424

FRESNO COUNTY
Department of Public Works and Planning
2220 Tulare Street, Suite 720
Fresno, CA 93721-2106

- A. BID FORMS AND CONTRACT CONDITIONS: No changes
- B. SPECIFICATIONS:
  - a. Section 000110 Table of Contents
    - Under Division 00 Procurement Contracting Requirements add the following section to the Table of Contents:
       "00 11 14 - LOCATION MAP"
  - b. Add Section 001114 Location Map, attached.
  - c. Section 133613 Self-Supporting Radio Tower
    - i. Part 2 Design, B. Design Requirements:
      - 1. Replace e) Provide lightning protection with: e) Provide a lightning rod at the top of the tower. Each antenna feeder will also require a polyphaser lightning arrestor.
      - 2. Add to j): Hangers shall be cushion type with 7 runs of 7/8" coaxial cable with N-Female Connectors at both ends. Antennas must come with N-Male Pigtails.
- C. DRAWINGS:
  - a. STRUCTURAL
    - i. S4 ROOF FRAMING PLAN, FOUNDATION PLAN
      - 1. Added the Generator Anchorage Detail.
  - b. ELECTRICAL
    - i. E03 ELECTRICAL BUILDING PLAN
      - 1. Added a 2"Ø Conduit for Fiber Optic

