

**ADDENDUM 01**

Contract # 24-S-04

Dated: July 1, 2024

The foregoing documents are amended in the respects as herein set forth. This addendum and the amendments herein shall become part of said documents and of any contract entered into pursuant to said documents.

**PLEASE ACKNOWLEDGE THIS ADDENDUM ON YOUR PROPOSAL. IF YOU HAVE GIVEN THE CONTRACT DOCUMENTS TO SOMEONE ELSE, PLEASE FORWARD THIS ADDENDUM.**

Jul 1, 2024

Date Signed



Engineer of Record:

A handwritten signature in blue ink that reads "Joe Harrell". Below the signature, the text "Joseph C. Harrell, P.E." is printed in a very small font.

Joseph C. Harrell, PE C80424

**FRESNO COUNTY**  
**Department of Public Works and Planning**  
m/a 2220 Tulare Street, Suite 720  
Fresno, CA 93721-2106

**A. SPECIFICATIONS:**

- a. Section 033000 Cast-In-Place Concrete
  - i. Paragraph 2.10, B:
    - a. Delete the following sentence: "Use fly ash, pozzolan, slag cement, and silica fume as needed to reduce the total amount of portland cement, which would otherwise be used, by not less than 40 percent."
  - ii. Paragraph 2.11, A:
    - a. Delete the following sentence: "Air Content: 6 percent, plus or minus 1.5 percent at point of delivery for 3/4-inch nominal maximum aggregate size."
  - iii. Paragraph 2.11, B:
    - a. Delete the following sentence: "Air Content: 6 percent, plus or minus 1.5 percent at point of delivery for 3/4-inch nominal maximum aggregate size."
  - iv. Paragraph 2.11, C:
    - a. Delete the following sentence: "Air Content: 6 percent, plus or minus 1.5 percent at point of delivery for 3/4-inch nominal maximum aggregate size."
    - b. Delete the following sentence: "Steel-Fiber Reinforcement: Add to concrete mixture, according to manufacturer's written instructions, at a rate of 50 lb/cu. yd." and replace with: "Synthetic Fiber Reinforcement: Add to concrete mixture, according to manufacturer's written instructions, using both macro and micro size fibers at a combined rate of 5 lbs/cu. yd."
  - v. Paragraph 2.5, C:
    - a. Replace this paragraph with the following:  
Normal-Weight Aggregates: ASTM C 33, Class 3S coarse aggregate or better, graded. Provide aggregates from a single source with documented service record data of at least 10 years' satisfactory service in similar applications and service conditions using similar aggregates and cementitious materials.  
  
1. Maximum Coarse-Aggregate Size: 1 inch nominal.  
2. Fine Aggregate: Free of materials with deleterious reactivity to alkali in cement.

**B. GENERAL CLARIFICATIONS:**

Refer to Responses to Requests for Clarifications published on the County's Bid page.